

227.810 Requirement for ground-fault circuit-interrupter installation on public fountains and pools -- Standards to be adopted by administrative regulations -- Prohibition of exemption by local governmental action.

- (1) A ground-fault circuit-interrupter shall be installed on all existing and new fountains and pools that are located in a public place within the Commonwealth, in accordance with standards set forth in the National Electrical Code adopted by administrative regulations of the department.
- (2) A state or local government agency shall not promulgate an administrative regulation or ordinance to exempt any fountain or pool located in a public place from the required installation of a ground-fault circuit-interrupter, regardless of the age of construction of the fountain or pool.

Effective: July 15, 2010

History: Amended 2010 Ky. Acts ch. 24, sec. 428, effective July 15, 2010. -- Created 1992 Ky. Acts ch. 6, sec. 2, effective January 1, 1993.