

“(cc) showing the serial number, manufacturer, and model number from the nameplate of the installed motor of the qualified entity on which the qualified extended product system was installed; or

“(II) in the case of a qualified entity described in paragraph (1)(B), demonstrated evidence—

“(aa) that the qualified extended product system meets the requirements of subsection (a)(4)(B); and

“(bb) showing the serial number, manufacturer, and model number from the nameplate of the installed motor of the qualified entity with which the extended product system is integrated.

“(d) AUTHORIZED AMOUNT OF REBATE.—

“(1) IN GENERAL.—The Secretary may provide to a qualified entity a rebate in an amount equal to the product obtained by multiplying—

“(A) an amount equal to the sum of the nameplate rated horsepower of—

“(i) the electric motor to which the qualified extended product system is attached; and

“(ii) the electronic control; and

“(B) \$25.

“(2) MAXIMUM AGGREGATE AMOUNT.—A qualified entity shall not be entitled to aggregate rebates under this section in excess of \$25,000 per calendar year.

“(e) AUTHORIZATION OF APPROPRIATIONS.—There is authorized to be appropriated to carry out this section \$5,000,000 for each of fiscal years 2022 and 2023.”

### § 6312. Purposes and coverage

#### (a) Congressional statement of purpose

It is the purpose of this part to improve the efficiency of electric motors and pumps and certain other industrial equipment in order to conserve the energy resources of the Nation.

#### (b) Inclusion of industrial equipment as covered equipment

The Secretary may, by rule, include a type of industrial equipment as covered equipment if he determines that to do so is necessary to carry out the purposes of this part.

#### (c) Inclusion of component parts of consumer products as industrial equipment

The Secretary may, by rule, include as industrial equipment articles which are component parts of consumer products, if he determines that—

(1) such articles are, to a significant extent, distributed in commerce other than as component parts for consumer products; and

(2) such articles meet the requirements of section 6311(2)(A) of this title (other than clauses (ii) and (iii)).

(Pub. L. 94-163, title III, §341, as added Pub. L. 95-619, title IV, §441(a), Nov. 9, 1978, 92 Stat. 3268.)

### § 6313. Standards

#### (a) Small, large, and very large commercial package air conditioning and heating equipment, packaged terminal air conditioners and heat pumps, warm-air furnaces, packaged boilers, storage water heaters, instantaneous water heaters, and unfired hot water storage tanks

(1) Each small commercial package air conditioning and heating equipment (including single package vertical air conditioners and single package vertical heat pumps) manufactured on

or after January 1, 1994, shall meet the following standard levels:

(A) The minimum seasonal energy efficiency ratio of air-cooled three-phase electric central air conditioners and central air conditioning heat pumps less than 65,000 Btu per hour (cooling capacity), split systems, shall be 10.0.

(B) The minimum seasonal energy efficiency ratio of air-cooled three-phase electric central air conditioners and central air conditioning heat pumps less than 65,000 Btu per hour (cooling capacity), single package, shall be 9.7.

(C) The minimum energy efficiency ratio of air-cooled central air conditioners and central air conditioning heat pumps at or above 65,000 Btu per hour (cooling capacity) and less than 135,000 Btu per hour (cooling capacity) shall be 8.9 (at a standard rating of 95 degrees F db).

(D) The minimum heating seasonal performance factor of air-cooled three-phase electric central air conditioning heat pumps less than 65,000 Btu per hour (cooling capacity), split systems, shall be 6.8.

(E) The minimum heating seasonal performance factor of air-cooled three-phase electric central air conditioning heat pumps less than 65,000 Btu per hour (cooling capacity), single package, shall be 6.6.

(F) The minimum coefficient of performance in the heating mode of air-cooled central air conditioning heat pumps at or above 65,000 Btu per hour (cooling capacity) and less than 135,000 Btu per hour (cooling capacity) shall be 3.0 (at a high temperature rating of 47 degrees F db).

(G) The minimum energy efficiency ratio of water-cooled, evaporatively-cooled and water-source central air conditioners and central air conditioning heat pumps less than 65,000 Btu per hour (cooling capacity) shall be 9.3 (at a standard rating of 95 degrees F db, outdoor temperature for evaporatively cooled equipment, and 85 degrees Fahrenheit entering water temperature for water-source and water-cooled equipment).

(H) The minimum energy efficiency ratio of water-cooled, evaporatively-cooled and water-source central air conditioners and central air conditioning heat pumps at or above 65,000 Btu per hour (cooling capacity) and less than 135,000 Btu per hour (cooling capacity) shall be 10.5 (at a standard rating of 95 degrees F db, outdoor temperature for evaporatively cooled equipment, and 85 degrees Fahrenheit entering water temperature for water source and water-cooled equipment).

(I) The minimum coefficient of performance in the heating mode of water-source heat pumps less than 135,000 Btu per hour (cooling capacity) shall be 3.8 (at a standard rating of 70 degrees Fahrenheit entering water).

(2) Each large commercial package air conditioning and heating equipment (including single package vertical air conditioners and single package vertical heat pumps) manufactured on or after January 1, 1995, but before January 1, 2010, shall meet the following standard levels:

(A) The minimum energy efficiency ratio of air-cooled central air conditioners and central air conditioning heat pumps at or above 135,000 Btu per hour (cooling capacity) and less than